

REMOVAL OF HEAVY METALS FROM INDUSTRIAL WASTEWATERS USING LOCAL ALUM AND OTHER CONVENTIONAL COAGULANTS - A COMPARATIVE STUDY

A.O. OGUNFOWOKAN⁺, L.M. DUROSINMI, J.A.O. OYEKUNLE,
O.A. OGUNKUNLE and I.T. IGBAFE

Department of Chemistry, Obafemi Awolowo University, Ile-Ife, 220005, Nigeria.

(Received: July, 2007; Accepted: December, 2007)

Abstract

Wastewater samples from battery, paint and textile industries were treated with different doses of locally available alum, aluminum sulphate and ferric chloride in order to determine and compare their effectiveness in removing heavy metal contents from the wastewaters. The percentage removal of the metals from the industrial wastewaters increased with mgL⁻¹ dosage of the coagulants used with optimal performance generally at a slightly alkaline pH. Local alum proved to be equally effective in removing heavy metals from the industrial wastewater samples compared with the conventional aluminium sulphate and ferric chloride.

Key words: Local alum, aluminum sulphate, ferric chloride, heavy metals, industrial wastewaters, coagulants.

1. Introduction

Many coagulants are widely used in conventional water-treatment processes for tap water production. These coagulants can be classified into inorganic coagulant, synthetic organic polymer and naturally occurring coagulant (Pitt *et al.*, 2004). These coagulants are used for various purposes depending on their chemical characteristics. An inorganic polymer, polyaluminium chloride and inorganic salt 'alum' (aluminium sulfate) are the most widely used coagulants in water treatment (Boisvert *et al.*, 1997 and Okuda *et al.*, 2001). Coagulation is a two-step process, the first step is destabilization of particles (by chemical addition), followed by amalgamation (by mixing) to form faster sinking particles (Fatoki and Ogunfowokan, 2002; WTA's World Wide Water, 2002; Pitt *et al.*, 2004). Coagulation is also useful in removing hydrophilic (water-loving) particles like organic colour-forming compounds which are usually difficult to remove by some other means. Chemicals commonly used in the coagulation process are inorganic salts of iron and aluminum such as aluminum sulphate, ferric chloride, ferric sulphate, cationic polymers, potash alum, ammonia aluminum and chlorinated copper (Jiang and Graham, 1998).

Effluents generated from industries contain pollutants especially heavy metals that are hazardous to the environment. Vast quantities of these heavy metals are discharged into the environment and are not biodegradable; they are also involved in a complex biogeochemical cycle. Due to toxicities caused by these heavy metals and pollutants in general to

humans and the environment, it is important that wastewaters have to be treated before disposal. The principal objective of wastewaters treatment is generally to allow industrial effluents to be disposed off without causing unacceptable damage to the natural environment.

Springing small-scale and even some large-scale industries in developing countries seldom have their effluents properly treated before discharging them into water bodies. This is done either in an attempt to cut cost since the conventional chemicals for wastewater treatment are considered costly or because the appropriate technology used by the developed countries (Johnson *et al.*, 2003; USInfrastructure, 2003) is expensive. As a result, the pollution level of streams and rivers around industrialized locations has tremendously increased. A review by Nriagu, (1992) has shown that the limited water resources available in Africa are now being contaminated with metals.

Somashakar *et al.* (1982) observed that the chemical composition of water results from different environmental factors operating simultaneously but with differing influences and efficiency. According to Ang *et al.* (1989), heavy metals are present in sea water as a result of both natural and anthropogenic activities. Apart from natural factors like weathering, human activities towards improving conditions of living have inadvertently introduced harmful substances into the environment WHO, (1971; 1977). Even though some trace elements are essential to man, essential

⁺ corresponding author (email: aogunfow@oauife.edu.ng)

as well as non-essential elements at elevated levels can cause morphological abnormalities, reduced growth, increased mortality and mutagenic effects in humans (Pier and Bang, 1980; Friberg *et al.*, 1986 and DWAF, 1996). Thus, efforts geared towards effective management and purification of wastewaters using cheaper and easily available materials are quite important.

In our preliminary work on the effect of coagulant treatment on the metal composition of raw water, two coagulants - $\text{Al}_2(\text{SO}_4)_3$ and $\text{Fe}_2(\text{SO}_4)_3$ were used. The results showed that apart from removing suspended matters both coagulants have additional advantage of being capable of removing metals with percentage removal enhanced with increased mgL^{-1} dosage of either coagulant used (Fatoki and Ogunfowokan, 2002). The present study is concerned with the application of coagulants - aluminum sulphate, ferric chloride and a locally available and widely used alum from South Western Nigeria (the local alum is used mainly for removal of suspended matter from water}, in the removal of heavy metals viz: Mn, Cr, Cd, Zn, Ni and Pb from industrial wastewaters. The three industries considered in this study are textile, battery and paint industries. Evaluation of the effectiveness of the coagulants in the removal of metals and the extent to which local alum may be used as a substitute to the conventional and more costly coagulants for the removal of toxic heavy metals from industrial waste waters was also reported. Interest in coagulation and hence removal of these metals stems from the fact that most of them may occur at levels that can cause deleterious effect on the health of humans if discharged into the environment especially into a receiving stream which serves as drinking water for rural dwellers downstream.

2. Materials and Methods

Sample Collection and Treatment:

Industrial wastewater samples from paint, textiles and battery industries from some parts of Western Nigeria were collected separately into polyethylene plastic bottles, which had been previously washed with detergent solution, soaked in 10% HNO_3 , and finally rinsed thoroughly with triply distilled water. The samples were transported to the laboratory and refrigerated at 4 °C prior to analysis.

Chemicals and Reagents:

All the chemicals used were of Analytical grade. The anhydrous reagents were placed in an oven at 105 °C for 12 hours to remove traces of water and then placed in a dessicator to prevent absorption of moisture from the atmosphere prior to usage. Triply distilled water was used for all reagent preparations.

Quality Control Study:

Recovery Work:

100 ml of triply distilled water was placed in each of six 250 ml beakers. Continuous stirring using a magnetic stirrer for each of the 100ml triply distilled water was carried out at a speed of 100 rev/min for 1 minute. The pH adjustment of the triply distilled water to 7.5 was done using 0.1 M H_2SO_4 or 0.2 M NaOH as necessary. Each of the distilled water was respectively spiked with 10 ppm of Zn^{2+} , Cd^{2+} , Cr^{6+} , Mn^{2+} , Pb^{2+} and Ni^{2+} mixture. Stirring of the spiked solutions at a speed of 100 rev/minutes was carried out for 15 minutes. About 75 ml of the stirred solution was placed in the pretreated sample bottle separately for analysis by Flame Atomic Absorption Spectrometer (FAAS) (Chemtech Analytical, UK.) at the Center for Energy Research and Development of the Obafemi Awolowo University, Ile-Ife, Nigeria. A 10 ppm each of the standards Zn^{2+} , Cd^{2+} , Cr^{6+} , Mn^{2+} , Pb^{2+} and Ni^{2+} were also analyzed by AAS and the results obtained were compared with those of spiked water samples to obtain the recovery of the analytes. The recovery of the added metals was determined for three parallel addition experiments. The recovery work was necessary to ascertain the efficiency of the analytical procedure described in this study.

A blank experiment was carried out with triply distilled water using the same procedure above omitting the standards to establish blank levels DWAF (1992).

Treatment of Industrial Wastewaters with Coagulants:

The pH of the wastewater samples was measured using a digital pH meter mode H (Hanna Instrument). The industrial wastewater samples were filtered through a 0.45 μm filter paper to remove large particulates. 250 ml of the filtered wastewater samples were placed in 500 ml beakers and stirred continuously using a magnetic stirrer at a speed of 100 rev/min. 0.1 M H_2SO_4 or 0.2 M NaOH was added to achieve the desired pH. The filtered wastewater samples were then coagulated with 3, 6 and 10ppm doses of $\text{Al}_2(\text{SO}_4)_3$ within the pH range of 5.9-7.5. Similarly, 3, 6 and 10 ppm of FeCl_3 and local alum were respectively used to coagulate wastewater samples within the same pH range mentioned above. After the addition of each coagulant, the stirring rate was accelerated to 300 rev/min for 3 minutes and then reduced to 100 rev/min for 15 minutes. The flocs formed were allowed to settle for 30 minutes after stirring had been completed. 25 ml of the resultant solution was taken from 10 ml below the solution surface and then filtered through a 0.45 μm filter paper. The filtrate was placed in the pretreated polyethylene sample bottle and analyzed by AAS.

Instrumentation:

The analyses of the treated and untreated samples were performed with Flame Atomic Absorption Spectrometer (FAAS) (Chemtech Analytical, UK.)

at the Center for Energy Research and Development of the Obafemi Awolowo University, Ile-Ife, Nigeria. Data were acquired on a Gateway 2000 PC system using the appropriate software. Six elements: Mn, Cr, Cd, Zn, Ni and Pb were determined using the above instrumentation and the percentage removal (% Removal) of each metal was estimated.

3. Results and Discussion

The results of the recovery work for the elements determined in this work are presented in Table 1. The percentage recovery (% Recovery) ranged from (60%) Pb to (85%) Mn. Results of the blank experiments for the metals in the study gave clean blank levels. These results thus validated the experimental procedure used for the chemical analysis. Table 2 shows the results of the heavy metal concentrations of the raw industrial wastewaters from three industries investigated in this study together with the total metal load in mgL^{-1} . The levels of the heavy metals in the raw industrial waste waters before treatment with the coagulants were: 3.01 mg Mn L^{-1} , 0.26 mg Cr L^{-1} , 4.01 mg Cd L^{-1} , 129.64 mg Zn L^{-1} , 1.88 mg Ni L^{-1} and 0.12 mg Pb L^{-1} in Battery industrial wastewater; 0.39 mg Mn L^{-1} , 0.01 mg Cr L^{-1} , 0.23 mg Cd L^{-1} , 0.59 mg Zn L^{-1} , 0.15 mg Ni L^{-1} and 0.11 mg Pb L^{-1} in the effluent from paint industry

and 0.28 mg Mn L^{-1} , 0.00 mg Cr L^{-1} , 0.20 mg Cd L^{-1} , 0.36 mg Zn L^{-1} , 0.05 mg Ni L^{-1} and 0.00 mg Pb L^{-1} in textile industry wastewaters respectively. The total metal load was highest in battery industry (138.92 mg L^{-1}) and the least in textile industry (0.89 mg L^{-1}) Table 2. This shows that the wastewater from battery industry was the most polluted of the selected heavy metals in this study. This may be extremely toxic to humans and aquatic biota even at low concentrations (Leonard, 1991), if they are discharged continuously into fresh water bodies directly without their removal from the wastewaters and such water is consumed untreated by rural dwellers downstream.

Presently, only the effluent from the textile industry met with the effluent limitation guidelines stipulated by the Nigerian Ministry of Environment (formerly Federal Environmental Protection Agency) (FEPA, 1991) for all the metals analyzed (Table 2). There were violations of these guidelines for Cd and Pb in paint industry while in battery industry, violations of guidelines occurred for Cd, Zn, Ni and Pb (Table 2). This calls for concern more so that most industries in the study area discharge effluents into receiving surface waters either untreated or partially treated in spite of the campaign for proper treatment of effluents prior to their discharge into the environment by the Nigerian Ministry of Environment regulatory

Table 1: Recoveries of metals from spiked water sample

Element	Concentration (mgL^{-1})		% Recovery
	Amount added	Amount recovered	
Mn	10.0	8.50±0.08	85
Cr	10.0	8.40±0.07	84
Cd	10.0	8.00±0.13	80
Zn	10.0	7.30±0.11	73
Ni	10.0	6.30±0.15	63
Pb	10.0	6.00±0.09	60

Table 2: Trace metal concentration of raw industrial wastewater samples

Industry	Concentration of Trace Metals (mg L^{-1})						Total Load (mgL^{-1})
	Mn	Cr	Cd	Zn	Ni	Pb	
Battery	3.01 ±0.54 (5.0)	0.26±0.13 (<1.0)	4.01±0.29 (0.01)	129.64 ±5.33 (<1.0)	1.88±0.11 (0.05)	0.12±0.07 (0.01)	138.92
Paint	0.39 ±0.11 (5.0)	0.01±0.00 (1.0)	0.23±0.12 (0.01)	0.59±0.19 (1.0)	0.15±0.06 (1.0)	0.11±0.04 (0.01)	1.48
Textile	0.28 ±0.10 (5.0)	ND (<0.10)	0.20±0.08 (<1.0)	0.36±0.16 (<1.0)	0.05±0.01 (<1.0)	ND (<1.0)	0.89

Values in parenthesis are Nigerian national effluent limitation guidelines for industries for effluents for discharge into surface water (FEPA, 1991). ND = Not detected

Table 3: Tolerance limits of some trace metals in drinking water

Metal	Upper Limit of Concentration (mgL^{-1})
Mn*	0.05
Cr	0.05
Cd	0.01
Zn*	5.00
Ni	-
Pb	0.05
Hg	0.001

Source: WHO, 1971.

*Report of the Committee on Water Quality Criteria Federal Water Pollution Administration, Us Department of Interior, Washington DC,

Table 4: Removal of heavy metals from industrial wastewaters by aluminum sulphate [$Al_2(SO_4)_3$].

Industry	Coagulant Dosage (mgL^{-1})	pH	Change in Concentration (mgL^{-1})						% Removal					
			Mn	Cr	Cd	Zn	Ni	Pb	Mn	Cr	Cd	Zn	Ni	Pb
Battery	0	5.94	3.01 ± 0.07	0.26 ± 0.3	4.013 ± 0.243	129.640 ± 2.741	1.88 ± 0.21	0.12 ± 0.03	0.00	0.00	0.00	0.00	0.00	0.00
	3	7.20	1.43 ± 0.21	0.03 ± 0.01	0.004 ± 0.001	0.008 ± 0.002	1.40 ± 0.11	0.08 ± 0.02	52.50	88.50	99.90	99.90	25.50	33.30
	6	7.30	1.35 ± 0.10	0.02 ± 0.00	0.00	0.00	1.20 ± 0.07	0.01 ± 0.00	55.10	92.30	100.00	100.00	36.20	91.70
	10	7.50	1.34 ± 0.12	0.01 ± 0.01	0.00	0.00	1.20 ± 0.03	0.00 ± 0.00	55.50	96.20	100.00	100.00	36.20	100.00
Paint	0	5.94	0.39 ± 0.09	0.01 ± 0.00	0.230 ± 0.006	0.591 ± 0.019	0.15 ± 0.08	0.11 ± 0.06	0.00	0.00	0.00	0.00	0.00	0.00
	3	7.20	0.15 ± 0.05	0.00	0.00	0.001 ± 0.01	0.00	0.05 ± 0.02	61.70	100.00	99.80	99.80	100.00	95.50
	6	7.30	0.06 ± 0.00	0.00	0.00	0.00	0.00	0.00	84.70	100.00	100.00	100.00	100.00	100.00
	10	7.50	0.04 ± 0.01	0.00	0.00	0.00	0.00	0.00	89.80	100.00	100.00	100.00	100.00	100.00
Textile	0	5.94	0.28 ± 0.11	0.00 ± 0.00	0.197 ± 0.094	0.360 ± 0.083	0.05 ± 0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	3	7.20	0.01 ± 0.01	0.00	0.00	0.00	0.00	0.00	96.50	0.00	100.00	100.00	100.00	0.00
	6	7.30	0.00	0.00	0.00	0.00	0.00	0.00	100.00	0.00	100.00	100.00	100.00	0.00
	10	7.50	0.00	0.00	0.00	0.00	0.00	0.00	100.00	0.00	100.00	100.00	100.00	0.00

Table 5: Removal of heavy metals from industrial wastewaters by ferric chloride ($FeCl_3$).

Industry	Coagulant Dosage (mgL^{-1})	pH	Change in Concentration (mgL^{-1})						% Removal					
			Mn	Cr	Cd	Zn	Ni	Pb	Mn	Cr	Cd	Zn	Ni	Pb
Battery	0	5.94	3.01 ± 0.05	0.26 ± 0.01	4.013 ± 0.110	129.640 ± 5.021	1.88 ± 0.30	0.12 ± 0.02	0.00	0.00	0.00	0.00	0.00	0.00
	3	7.20	1.71 ± 0.22	0.03 ± 0.01	0.008 ± 0.002	0.018 ± 0.001	1.60 ± 0.22	0.00	43.20	88.50	99.80	99.90	14.90	100.00
	6	7.30	1.54 ± 0.02	0.00	0.008 ± 0.002	0.007 ± 0.003	1.50 ± 0.09	0.00	48.80	100.00	99.80	100.00	20.20	100.00
	10	7.50	1.42 ± 0.16	0.00	0.005 ± 0.002	0.00	1.30 ± 0.15	0.00	52.80	100.00	99.80	100.00	30.90	100.00
Paint	0	5.94	0.39 ± 0.11	0.01 ± 0.01	0.230 ± 0.081	0.591 ± 0.062	0.15 ± 0.04	0.11 ± 0.06	0.00	0.00	0.00	0.00	0.00	0.00
	3	7.20	0.07 ± 0.01	0.01 ± 0.01	0.003 ± 0.001	0.005 ± 0.001	0.00	0.02 ± 0.01	82.10	0.00	98.70	99.20	100.00	81.80
	6	7.30	0.06 ± 0.02	0.00	0.00	0.00	0.00	0.00	84.70	100.00	100.00	100.00	100.00	100.00
	10	7.50	0.04 ± 0.02	0.00	0.00	0.00	0.00	0.00	89.80	100.00	100.00	100.00	100.00	100.00
Textile	0	5.94	0.28 ± 0.07	0.00	0.197 ± 0.019	0.360 ± 0.008	0.05 ± 0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	3	7.20	0.03 ± 0.01	0.00	0.003 ± 0.001	0.008 ± 0.001	0.00	0.00	89.40	0.00	98.50	87.70	100.00	0.00
	6	7.30	0.01 ± 0.01	0.00	0.00	0.00	0.00	0.00	96.50	0.00	100.00	100.00	100.00	0.00
	10	7.50	0.00	0.00	0.00	0.00	0.00	0.00	100.00	0.00	100.00	100.00	100.00	0.00

Table 6: Removal of heavy metals from industrial wastewaters by local alum

Industry	Coagulant Dosage (mgL ⁻¹)	pH	Change in Concentration (mgL ⁻¹)						% Removal					
			Mn	Cr	Cd	Zn	Ni	Pb	Mn	Cr	Cd	Zn	Ni	Pb
Battery	0	5.94	3.01 ± 0.10	0.26 ± 0.02	4.013 ± 0.150	129.640 ± 0.112	1.88 ± 0.14	0.12 ± 0.05	0.00	0.00	0.00	0.00	0.00	0.00
	3	7.20	0.04 ± 0.01	0.19 ± 0.05	3.182 ± 0.234	67.672 ± 0.157	0.70 ± 0.25	0.06 ± 0.01	98.70	26.90	20.70	47.80	62.80	50.00
	6	7.30	0.02 ± 0.01	0.15 ± 0.07	2.243 ± 0.211	67.154 ± 0.374	0.67 ± 0.33	0.04 ± 0.00	99.40	42.30	44.10	48.20	64.40	66.70
	10	7.50	0.01 ± 0.00	0.00 ± 0.00	0.542 ± 0.098	45.892 ± 2.321	0.66 ± 0.20	0.03 ± 0.01	99.70	100.00	86.50	64.60	64.90	75.00
Paint	0	5.94	0.390 ± 0.015	0.010 ± 0.001	0.230 ± 0.07	0.591 ± 0.065	0.15 ± 0.01	0.11 ± 0.02	0.00	0.00	0.00	0.00	0.00	0.00
	3	7.20	0.002 ± 0.001	0.008 ± 0.003	0.208 ± 0.097	0.489 ± 0.08	0.10 ± 0.08	0.07 ± 0.00	99.50	20.00	9.60	17.30	33.30	36.40
	6	7.30	0.002 ± 0.000	0.007 ± 0.002	0.100 ± 0.08	0.434 ± 0.20	0.09 ± 0.02	0.05 ± 0.01	99.50	30.00	56.50	26.60	40.00	54.40
	10	7.50	0.001 ± 0.001	0.00	0.061 ± 0.005	0.321 ± 0.019	0.08 ± 0.03	0.01 ± 0.00	99.70	100.00	73.50	45.70	46.70	90.90
Textile	0	5.94	0.280 ± 0.121	0.00	0.197 ± 0.027	0.360 ± 0.026	0.05 ± 0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	3	7.20	0.002 ± 0.001	0.00	0.155 ± 0.061	0.330 ± 0.093	0.03 ± 0.01	0.00	99.30	0.00	21.30	8.30	40.00	0.00
	6	7.30	0.002 ± 0.001	0.00	0.070 ± 0.008	0.194 ± 0.10	0.027 ± 0.01	0.00	99.30	0.00	64.50	46.10	46.00	0.00
	10	7.50	0.00	0.00	0.029 ± 0.004	0.119 ± 0.032	0.026 ± 0.011	0.00 ± 0.00	100.00	0.00	85.50	66.90	47.90	0.00

body. The high levels of some of these metals reported in the raw wastewaters especially for paint and battery industries show that interest in the coagulation processes and hence the removal of the heavy metals from the industrial wastewaters prior to their discharge into surface waters is of great importance because these metals may constitute a threat to human health particularly that levels of most of the metals in the wastewaters for all the categories of industries studied were presently above the minimum allowable threshold in water intended for human consumption (Table 3). Two or more poisons present together in water may exert additive, antagonistic or synergistic effects (Mason, 1996). For example, Ni and Cr act synergistically while Zn and Cu have negative additive effects on marine organism.

Table 4-6 show the results of removal of heavy metals from the various industrial wastewaters using $Al_2(SO_4)_3$, $FeCl_3$ and local alum respectively. It is evident from these results that as the dosage and pH increase, percentage removal of the heavy metals from the industrial wastewaters generally increased reaching an optimum level at pH 7.5 and dosage 10 mg L⁻¹ of the various coagulants used.

In the battery industry, local alum gave 99.70% efficiency of Mn removal and proved to be the best coagulant for removing Mn at 10 mg L⁻¹ dosage. Both local alum and ferric chloride gave significant removal of Cr (VI) (100.00%) while aluminum sulphate removed 96.20% Cr (VI) from the waste water at 10 mg L⁻¹ dosage of the coagulants. The results for the Cd removal from battery industry wastewater samples showed that local alum gave the least percentage removal of 86.50%, while 100.00% and 99.80% percentage removal were obtained respectively for aluminum sulphate and ferric chloride at pH 7.50 and 10 mg L⁻¹ coagulant dosage. Local

alum was best suitable for removing Ni having the highest percentage removal of 64.90% while the percentage removal of Ni by ferric chloride and aluminum sulphate were 30.90% and 36.20% respectively at 10 mg L⁻¹ coagulant dosage (Table 4-6). Our results further showed that local alum even at lower dosages of 3 to 6 mg L⁻¹ is the best coagulant for removing Ni from the Battery industrial wastewater compared to other conventional coagulants. Treatment of the wastewaters with $FeCl_3$ best removed Pb followed by $Al_2(SO_4)_3$ and local alum respectively.

In the paint industry, local alum gave the best percentage removal of Mn (99.70%) compared to $Al_2(SO_4)_3$ (89.80%) and $FeCl_3$ (89.80%) at 10 mg L⁻¹ coagulant dosage and pH 7.50 (Table 4-6). This observation is consistent with what was observed for the removal of Mn in Battery wastewater. Local alum percentage efficiency of removal for Zn and Ni from the wastewater of paint industry however, was less than those of the other two coagulants investigated in this study. Furthermore, local alum gave 90.90% percentage removal of Pb from paint industrial wastewater whereas other coagulants gave 100% removal.

Although $Al_2(SO_4)_3$ and $FeCl_3$ showed significant removal of Mn, Cd Zn and Ni (100%) from textile industrial wastewater, local alum also showed an acceptable percentage removal of Mn (100%), Cd (85.50%) and Zn (66.90%) from the wastewater at 10 mg L⁻¹ dosage of the coagulants. It is worth mentioning however that the removal of Ni from the textile wastewater by the local alum was small (47.90%).

This study has shown that there is a general increase in the percentage removal of metals from industrial wastewaters with increased dosage of coagulants.

Apart from the fact that local alum was the best coagulant for the removal of Mn and Ni from all the three industrial wastewaters, its performance for the removal of all other metals is equally effective compared with the other conventional coagulants used in this study. Judging from these results local alum may therefore be used as a substitute for the conventional and more costly coagulants for the removal of heavy metals from industrial waste waters.

4. Conclusion

In this study, local alum, $Al_2(SO_4)_3$ and $FeCl_3$ were investigated for their effectiveness in removing heavy metals from wastewaters from battery, paint and textile industries. The percentage removal of the metals from the industrial wastewaters increased with the dosage of the coagulants used with optimal performance at a slightly alkaline pH. All the coagulants apart from removing turbidity from the wastewaters also showed their capabilities of removing heavy metals. The local alum proved to be a cheap and effective coagulant in the removal of heavy metals from industrial wastewaters and may be used as a substitute to the conventional coagulants.

REFERENCES

- Ang, K.P., Tay, B. T., Gunasingham, H., Khoo, S.B. and Koh, C.H., 1989. The Determination of Heavy Metal Content in the Coastal Sea Waters of Singapore. *International Journal of Environmental Studies*, 32, 261.
- Boisvert, J.P., To, T.C., Berrak, A. and Jolicoeur, C., 1997. Phosphate Adsorption and Flocculation Processes of Aluminum Sulphate and Poly-aluminum-silicate-sulphate. *Water Research*, 31, 1939.
- Department of Water Affairs and Forestry (DWAf), 1992. Analytical Methods Manual, TR 151, DWAf, Pretoria.
- Department of Water Affairs and Forestry (DWAf), 1996a. Water Quality Guidelines, Domestic use, Vol.1 (2nd edn.), DWAf, Pretoria.
- Fatoki, O.S. and Ogunfowokan, A.O., 2002. Effect of Coagulant Treatment on the Metal Composition of Raw Water. *Water S.A.* 28(3), 293.
- Federal Environmental Protection Agency (FEPA), 1991. National Interim Guidelines and Standards for Industrial Effluents, Gaseous Emissions and Hazardous Wastes Management in Nigeria, 33.
- Friberg, L., Kjellstrom, T. and Nordberg, G.F., 1986. In *Handbook on the Toxicology of Metals*, L. Friberg, G.F. Nordberg and V.B. Vonk (Eds.), Elsevier, Amsterdam, New York, Oxford, 11, 130.
- Jiang, J.Q. and Graham, N.J.D., 1998. Pre-polymerized Inorganic Coagulants and Phosphorus Removal by Coagulation: A review. *Water S.A.* 24 (3), 237.
- Johnson, P.D., Pitt, R., Durrans, S.R., Urrutia, M. and Clark, S., 2003. Innovative Metals Removal Technologies for Urban Stormwater. Water Environment Research Foundation, WERF 97-IRM-2, Alexandria, VA.
- Leonard, A., 1991. Arsenic. In: *Metals and their Compounds in the Environment: Occurrence, Analysis and Biological Relevance*, E. Merian (Ed.), VC H, Weinheim, Cambridge, 751.
- Mason, C.F., 1996. In: *Pollution, Causes, Effects and Control*, R.M. Harrison (Ed.), Pub. The Royal Society of Chemistry, Cambridge, UK, 66.
- Nriagu, J.O., 1992. "Toxic Metal Pollution in Africa". *Science Total Environment*, 121, 1-37.
- Okuda, T., Baes, A.U., Nishijima, W. and Okada, M., 2001. Isolation and Characterization of Coagulant Extracted from *Moringa oleifera* seed by Salt Solution. *Water Research*, 35 (2), 405.
- Pier, S.M. and Bang, M.K., 1980. In: *Ann Arbor Science*, N.M. Trieff (Ed), The Butterworth Group Publ., 367.
- Pitt, R., Clark S., Johnson, P.D., Morquecho, R., Gill, S. and Pratap M., 2004. High Level Treatment of Stormwater Heavy Metals. *Water World and Environmental Resources Conference 2004*, Environmental and Water Resources Institute of the American Society of Civil Engineers, Salt Lake City, Utah, July 27-June 1, 2004.
- Somashekar, R.K., Ramaswamy, S.N. and Arekal, G.D., 1982. Trace Metal Concentrations of the Waters of a South Indian River. *International Journal of Environmental Studies*, 20, 63.
- US Infrastructure, (2003). Upflow Filters for the Rapid and Effective Treatment of Stormwater at Critical Source Areas. SBIR phase-I final report, US.
- Environmental Protection Agency, Washington, D.C. 2003.
- World Health Organisation (WHO), 1971. International Standard for Drinking Water, 3rd edition, WHO, Geneva.
- World Health Organisation (WHO), 1977. Lead: Environmental Health Criteria 3, WHO, Geneva.
- WTA's World Wide Water, 2002. Coagulation, 1-5. Coagulation.htm.